




LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K	TYPE:	WEIGHT:
SPEC.: 3500K 90	DIM.:	SERIAL No.:
MFR.: RP LIGHTING	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 80.34 lm/W			
MODEL	8744WH-90-5CCT 3500K	I _{max} (cd)	311.6	S/MH (C0/180)	1.27
NOMINAL POWER (W)	12	LOR (%)	100.0	S/MH (C90/270)	1.26
RATED VOLTAGE (V)	120.0	TOTAL FLUX (lm)	883.04	η UP, DN (C0-180)	0.0, 50.0
NOMINAL FLUX (lm)	883.035	CIE CLASS	DIRECT	η UP, DN (C180-360)	0.0, 50.0
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM	1.25
TEST VOLTAGE (V)	120	η down (%)	100.0	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT: lx)



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3 °C
Operators:
Test Date: 2023-06-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity: 65.0%
Test Distance: 3.080m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	304.5	305.2	305.6	305.8	306.2	306.3	306.1	305.1	0- 10	29.43	29.43	3.33,3.33
20	287.2	287.9	289.2	290.3	291.0	290.4	289.9	288.5	10- 20	84.33	113.8	12.9,12.9
30	260.2	261.3	263.0	264.2	265.0	264.6	263.4	261.9	20- 30	127.8	241.6	27.4,27.4
40	224.5	226.1	227.9	229.0	230.2	229.8	228.4	226.4	30- 40	154.1	395.7	44.8,44.8
50	181.7	183.3	185.2	186.3	187.0	186.6	185.7	183.5	40- 50	159.8	555.5	62.9,62.9
60	133.4	135.5	137.0	137.7	138.3	137.7	136.5	134.9	50- 60	144.0	699.5	79.2,79.2
70	81.91	84.25	85.95	86.58	86.42	85.48	84.79	83.46	60- 70	109.5	809.0	91.6,91.6
80	27.19	32.22	37.01	33.54	30.83	33.19	35.67	30.04	70- 80	61.62	870.6	98.6,98.6
90	0.3084	0.3280	0.3527	0.3210	0.1741	0.1945	0.2237	0.1934	80- 90	12.42	883.0	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3℃
 Operators:
 Test Date:2023-06-29

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
 Humidity:65.0%
 Test Distance:3.080m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz		
UTHDi:0.00% ITHDi:0.00% KDisp:0Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K	TYPE:	WEIGHT:
SPEC.: 3500K 90	DIM.:	SERIAL No.:
MFR.: RP LIGHTING	SUR.:	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	352	1645
80	1409	1918
75	1879	2108
70	2155	2262
65	2299	2373
60	2400	2467
55	2479	2537
50	2544	2593
45	2593	2641


C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2023-06-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.080m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz		
UTHDi:0.00% ITHDi:0.00% KDisp:0		
Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K	TYPE:	WEIGHT:
SPEC.: 3500K 90	DIM.:	SERIAL No.:
MFR.: RP LIGHTING	SUR.:	Shielding Angle:

ρcc	80%			70%			50%			30%			10%			0
ρw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3°C
 Operators:
 Test Date: 2023-06-29

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
 Humidity: 65.0%
 Test Distance: 3.080m [K=1.0000]
 Remarks:

WEC AND CCEC

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz			UTHDi:0.00% ITHDi:0.00% KDisp:0			Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K			TYPE:			WEIGHT:		
SPEC.: 3500K 90			DIM.:			SERIAL No.:		
MFR.: RP LIGHTING			SUR.:			Shielding Angle:		

pcc	80%			70%			50%			30%			10%			0														
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0														
pfc	20%			20%			20%			20%			20%			0														
RCR	RCR:Room Cavity Ratio															Wall Exitance Coefficients(WEC)														
0.0																														
1.0	.305	.173	.055	.298	.170	.054	.285	.163	.052	.272	.157	.050	.261	.151	.049															
2.0	.289	.159	.049	.283	.156	.048	.271	.151	.047	.261	.146	.046	.251	.142	.045															
3.0	.269	.143	.043	.263	.141	.042	.253	.137	.042	.243	.133	.041	.234	.130	.040															
4.0	.248	.129	.038	.243	.127	.038	.234	.124	.037	.226	.121	.037	.218	.118	.036															
5.0	.230	.117	.034	.225	.116	.034	.217	.113	.033	.210	.111	.033	.203	.108	.033															
6.0	.213	.107	.031	.209	.106	.030	.202	.104	.030	.195	.102	.030	.189	.100	.030															
7.0	.199	.098	.028	.195	.097	.028	.189	.095	.027	.183	.094	.027	.177	.092	.027															
8.0	.185	.091	.025	.182	.090	.025	.177	.088	.025	.171	.087	.025	.166	.085	.025															
9.0	.174	.084	.023	.171	.083	.023	.166	.082	.023	.161	.081	.023	.156	.079	.023															
10.0	.163	.078	.022	.161	.078	.022	.156	.077	.022	.152	.075	.021	.148	.074	.021															

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.180	.156	.135	.154	.134	.116	.105	.092	.080	.061	.053	.047	.019	.017	.015	
2.0	.172	.132	.098	.147	.114	.085	.101	.079	.059	.058	.046	.035	.019	.015	.011	
3.0	.164	.114	.074	.141	.099	.065	.097	.068	.045	.056	.040	.027	.018	.013	.009	
4.0	.157	.101	.058	.134	.087	.051	.092	.061	.036	.053	.036	.021	.017	.012	.007	
5.0	.149	.091	.047	.128	.078	.041	.088	.055	.029	.051	.032	.017	.016	.010	.006	
6.0	.142	.082	.039	.122	.071	.034	.084	.050	.024	.049	.029	.014	.016	.010	.005	
7.0	.135	.075	.033	.116	.065	.029	.080	.046	.021	.047	.027	.012	.015	.009	.004	
8.0	.129	.069	.029	.111	.060	.025	.077	.042	.018	.045	.025	.011	.014	.008	.004	
9.0	.123	.065	.025	.106	.056	.022	.073	.039	.016	.043	.023	.009	.014	.008	.003	
10.0	.117	.060	.022	.101	.052	.020	.070	.037	.014	.041	.022	.008	.013	.007	.003	

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2023-06-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.080m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:883.035x1 lm											
NAME: 8744WH-90-5CCT 3500K						TYPE:		WEIGHT:			
SPEC.: 3500K 90						DIM.:		SERIAL No.:			
MFR.: RP LIGHTING						SUR.:		Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H		16.5	18.0	16.7	18.2	18.4	16.6	18.1	16.8	18.3	18.5
	3H	17.9	19.3	18.2	19.6	19.8	18.1	19.5	18.4	19.7	20.0
	4H	18.5	19.8	18.8	20.1	20.3	18.7	20.1	19.0	20.3	20.6
	6H	18.8	20.0	19.1	20.3	20.6	19.2	20.4	19.5	20.7	21.0
	8H	18.8	20.0	19.2	20.3	20.6	19.3	20.5	19.6	20.8	21.1
	12H	18.8	20.0	19.1	20.3	20.6	19.4	20.6	19.7	20.9	21.2
4H	2H	17.1	18.4	17.4	18.7	18.9	17.2	18.5	17.5	18.7	19.0
	3H	18.7	19.9	19.1	20.2	20.5	18.9	20.1	19.2	20.3	20.7
	4H	19.4	20.5	19.8	20.8	21.1	19.6	20.7	20.0	21.0	21.3
	6H	19.8	20.8	20.2	21.1	21.5	20.2	21.2	20.6	21.5	21.9
	8H	19.9	20.8	20.3	21.1	21.5	20.4	21.3	20.8	21.6	22.0
	12H	19.9	20.7	20.3	21.1	21.5	20.5	21.3	21.0	21.7	22.1
8H	4H	19.7	20.6	20.1	20.9	21.3	19.9	20.8	20.3	21.1	21.5
	6H	20.2	20.9	20.6	21.3	21.8	20.6	21.3	21.0	21.7	22.1
	8H	20.3	21.0	20.8	21.4	21.8	20.9	21.5	21.3	21.9	22.4
	12H	20.3	20.9	20.8	21.3	21.8	21.1	21.6	21.5	22.1	22.5
12H	4H	19.7	20.5	20.1	20.9	21.3	19.9	20.7	20.3	21.1	21.5
	6H	20.2	20.9	20.7	21.3	21.8	20.6	21.3	21.1	21.7	22.1
	8H	20.4	20.9	20.9	21.4	21.9	20.9	21.5	21.4	21.9	22.4
Variations with the observer position at spacings(CIE Pub.117):											
S = 1.0H		+ 0.2 / - 0.2					+ 0.2 / - 0.2				
1.5H		+ 0.2 / - 0.3					+ 0.2 / - 0.3				
2.0H		+ 0.2 / - 0.3					+ 0.2 / - 0.3				

CIE Pub.117, 883.0 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -0.4)
 Area: 0.111111 m2

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3℃
 Operators:
 Test Date:2023-06-29

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
 Humidity:65.0%
 Test Distance:3.080m [K=1.0000]
 Remarks:

UTILIZATION FACTORS TABLE

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K	TYPE:	WEIGHT:
SPEC.: 3500K 90	DIM.:	SERIAL No.:
MFR.: RP LIGHTING	SUR.:	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	58	46	39	57	46	39	56	45	39	32
0.80	68	56	49	67	56	49	65	55	48	41
1.00	76	65	58	75	64	57	73	66	57	50
1.25	83	73	66	82	72	65	79	71	64	57
1.50	88	78	71	87	78	71	84	76	70	62
2.00	95	87	80	93	85	79	90	83	78	70
2.50	99	91	85	97	90	84	93	87	83	74
3.00	102	96	90	100	94	89	96	91	87	78
4.00	106	101	96	104	99	95	100	96	92	83
5.00	109	104	100	106	102	99	102	99	95	86
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3°C
 Operators:
 Test Date: 2023-06-29

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
 Humidity: 65.0%
 Test Distance: 3.080m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K	TYPE:	WEIGHT:
SPEC.: 3500K 90	DIM.:	SERIAL No.:
MFR.: RP LIGHTING	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 2023-06-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity: 65.0%
Test Distance: 3.080m [K=1.0000]
Remarks:

AAI Figure

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K	TYPE:	WEIGHT:
SPEC.: 3500K 90	DIM.:	SERIAL No.:
MFR.: RP LIGHTING	SUR.:	Shielding Angle:




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 2023-06-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity: 65.0%
Test Distance: 3.080m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K	TYPE:	WEIGHT:
SPEC.: 3500K 90	DIM.:	SERIAL No.:
MFR.: RP LIGHTING	SUR.:	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 2023-06-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity: 65.0%
Test Distance: 3.080m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K	TYPE:	WEIGHT:
SPEC.: 3500K 90	DIM.:	SERIAL No.:
MFR.: RP LIGHTING	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	2349
L_0~180 (75) av	1952
L_0~180 (85) av	484
L_90~270 (65) av	2366
L_90~270 (75) av	2085
L_90~270 (85) av	1563
L_45 (65) av	2357
L_45 (75) av	2035
L_45 (85) av	822

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2023-06-29

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.080m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3 °C
Operators:
Test Date: 2023-06-29

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity: 65.0%
Test Distance: 3.080m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:119.85V I:0.0939A P:10.991W PF:0.9764 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:883.035x1 lm		
NAME: 8744WH-90-5CCT 3500K	TYPE:	WEIGHT:
SPEC.: 3500K 90	DIM.:	SERIAL No.:
MFR.: RP LIGHTING	SUR.:	Shielding Angle:

Table--1

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3 °C
Operators:
Test Date: 2023-06-29

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.080m [K=1.0000]
Remarks:

```